



EL DORADO IRRIGATION DISTRICT

District Approved Backflow Prevention Assemblies

August 27, 2019

APPLICATION	TYPE	SIZE	MAKE	MODEL
BACKFLOW PREVENTION ASSEMBLIES FOR DRINKING WATER CONNECTIONS	REDUCED PRESSURE PRINCIPLE BACKFLOW PREVENTION ASSEMBLY (RP)	3/4" – 2"	WILKINS WATTS FEBCO	975XL2, 375XL LF909 LF825Y
	*LEAD FREE	2 1/2" – 10"	WILKINS	375AST, 475ST

APPLICATION	TYPE	SIZE	MAKE	MODEL
BACKFLOW PREVENTION ASSEMBLY FOR DRINKING WATER CONNECTIONS SERVING RESIDENTIAL DUAL-PLUMBED LOTS	DOUBLE CHECK BACKFLOW PREVENTION ASSEMBLY (DC) *LEAD FREE	3/4"	WILKINS	350XL

APPLICATION	TYPE	SIZE	MAKE	MODEL
BACKFLOW PREVENTION ASSEMBLIES FOR PRIVATE FIRE SERVICE CONNECTIONS	REDUCED PRESSURE PRINCIPLE DETCTOR ASSEMBLY (RPDA)	2 1/2" - 10"	WILKINS	375ASTDA, 475STDA

*Please be aware that California State Law has changed with regard to lead content in plumbing fixtures, including backflow prevention assemblies, installed after December 31, 2009. AB 1953, Section 116875 (a) states “No person shall use any pipe, pipe or plumbing fitting or fixture, solder or flux that is not lead free in the installation or repair of any public water system or any plumbing in a facility providing water for human consumption, except when necessary for the repair of leaded joints of cast iron pipes.” This list of EID approved backflow prevention assemblies meets this new requirement.